

AR No. 3

Insulate Cookers

Recommended Action

Insulate the two can cookers with two-inch fiberglass batted insulation covered with a foil jacket for protection.

Assessment Recommendation Summary			
Energy (10 ⁶ Btu)	Cost Savings	Implementation Cost	Payback (years)
116	\$540	\$345	0.6

Background

Currently the two can cookers have no insulation and are releasing a large amount of heat into the plant. By adding insulation the majority of this heat will be contained and result in a reasonable savings.

Anticipated Savings

The existing energy loss (E_0) can be found from:

$$\begin{aligned} E_0 &= [U_0 \times ((A_{C1} + A_{C2}) \times (T_S - T_A))] \times H \\ &= [2 \text{ Btu/ht-}^\circ\text{F-ft}^2 \times ((245 + 180) \text{ ft}^2 \times (180 - 10) ^\circ\text{F})] \times 1,344 \text{ hr/yr} \\ &= 125.7 \times 10^6 \text{ Btu/yr} \end{aligned}$$

where

$$\begin{aligned} U_0 &= \text{Existing Heat Transfer Coefficient: } 2 \text{ Btu/hr-}^\circ\text{F-ft} \\ A_{C1} &= \text{Area of Larger Cooker: } 245 \text{ ft}^2 \\ A_{C2} &= \text{Area of Smaller Cooker: } 180 \text{ ft}^2 \\ T_S &= \text{Surface Temperature of the Tanks: } 180 ^\circ\text{F} \\ T_A &= \text{Ambient Temperature: } 70 ^\circ\text{F} \\ H &= \text{Annual Operating Hours: } 1,344 \text{ hr/yr} \end{aligned}$$

The Energy loss after 2 inches of fiberglass batted insulation and a foil jacket (E_1) can be found from:

$$\begin{aligned}
 E_1 &= [U_1 \times ((A_{C1} + A_{C2}) \times (T_S - T_A))] \times H \\
 &= [0.16 \text{ Btu/hr-}^\circ\text{F-ft}^2 \times ((245 + 180) \text{ ft}^2 \times (180 - 70) ^\circ\text{F})] \times 1,344 \text{ hr/yr} \\
 &= 10.1 \times 10^6 \text{ Btu/yr}
 \end{aligned}$$

where

$$\begin{aligned}
 U_1 &= \text{Proposed Heat Transfer Coefficient} \\
 &= 1/(1/U_0 + 1/R) \\
 &= 1/(1/2 + 1/0.17) \\
 &= 0.16 \text{ Btu/hr-}^\circ\text{F-ft}^2 \\
 R &= \text{Insulation R-Value} \\
 &= \text{Thermal Conduction/Inches of Insulation} \\
 &= (0.34 \text{ Btu-in/ft}^2\text{-hr-}^\circ\text{F})/2\text{-in} \\
 &= 0.16 \text{ Btu/ft}^2\text{-hr-}^\circ\text{F}
 \end{aligned}$$

The energy savings (ES) can be found from:

$$\begin{aligned}
 ES &= (E_0 - E_1) \\
 &= (125.7 - 10.1) \times 10^6 \text{ Btu/yr} \\
 &= 115.6 \times 10^6 \text{ Btu/yr}
 \end{aligned}$$

The cost savings (CS) can be found from:

$$\begin{aligned}
 CS &= ES \times \$4.6924 / 10^6 \text{ Btu} \\
 &= 115.6 \times 10^6 \text{ Btu/yr} \times \$4.6924 / 10^6 \text{ Btu} \\
 &= \$540/\text{yr}
 \end{aligned}$$

Savings Summary				
Source	Quantity	Units	Energy 10 ⁶ Btu	Cost \$
Natural Gas	1,156	Therms	116	\$540

Implementation Cost

In addition to the two inches of fiberglass batted insulation, a foil jacket will be necessary for protection. The cost of the insulation and the jacket used below include installation.

The implementation cost (IC) can be found from:

$$\begin{aligned}
 IC &= (A_{C1} + A_{C2}) \times [(\text{Insulation Cost}) + (\text{Cost of Jacket})] \\
 &= (245 + 180) \text{ ft}^2 \times [(\$0.50/\text{ft}^2) + (\$0.05/\text{ft}^2)] \\
 &= \$345
 \end{aligned}$$

The savings will pay for the implementation cost in 0.6 years.